

Date : 04/21/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 04/21/2025 09:00
 Onsite Hours :

ASEC Report ID : 80238
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather :
 Departure Time : 04/21/2025
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/21/2025	1	16.3	105.8	2025-012 SP	105.6	18.9	100.2	95	D6938	Pass
Location : Sewer line ssmh 1.0A, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	2	16.6	102.7	2025-012 SP	105.6	18.9	97.3	95	D6938	Pass
Location : Ssmh 1.0B, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	3	16.9	109.4	2025-011 SP	115.0	15.5	95.1	95	D6938	Pass
Location : Lot #39, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	4	15.3	111.1	2025-008 SP	115.7	14.7	96.0	95	D6938	Pass
Location : Lot #124, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	5	19.2	104.8	2025-012 SP	105.6	18.9	99.2	95	D6938	Pass
Location : Lot #122, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	6	14.1	113.4	2025-011 SP	115.0	15.5	98.6	95	D6938	Pass
Location : Lot #121, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/21/2025	07	19.8	103.2	2025-012 SP	105.6	18.9	97.7	95	D6938	Pass
Location : Lot #117, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

Date : 04/21/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 04/21/2025 09:00
Onsite Hours :

ASEC Report ID : 80238
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather :
Departure Time : 04/21/2025
ASEC Technician Name : Solomon Cherie

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/21/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 04/21/2025 09:00
 Onsite Hours :

ASEC Report ID : 80238
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather :
 Departure Time : 04/21/2025
 ASEC Technician Name : Solomon Cherie

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY