

Date : 04/25/2025  
 Project No : 2025C160  
 Client Company : Artisan  
 Arrival Time : 04/25/2025 9:30  
 Onsite Hours : 06:30

ASEC Report ID : 81689  
 Name of the Project : Rockmart Township - 115 Felton Drive  
 Project Location : Rockmart  
 Weather : cloudy  
 Departure Time : 04/25/2025 16:00  
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/25/2025	1	22	125.9	2025-012 SP	105.6	18.9	97.7	95	D6938	Pass
Location : Lot #21, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/25/2025	2	21	124.8	2025-012 SP	105.6	18.9	97.6	95	D6938	Pass
Location : Lot #120, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/25/2025	3	21.1	127.0	2025-012 SP	105.6	18.9	99.3	95	D6938	Pass
Location : Lot #119, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/25/2025	4	21.2	104.9	2025-012 SP	105.6	18.9	99.3	95	D6938	Pass
Location : Lot #116, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/25/2025	5	20.3	105.5	2025-012 SP	105.6	18.9	99.9	95	D6938	Pass
Location : Lot #117, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/25/2025	6	20	125.7	2025-012 SP	105.6	18.9	99.2	95	D6938	Pass
Location : Lot #118, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/25/2025  
 Project No : 2025C160  
 Client Company : Artisan  
 Arrival Time : 04/25/2025 9:30  
 Onsite Hours : 06:30

ASEC Report ID : 81689  
 Name of the Project : Rockmart Township - 115 Felton Drive  
 Project Location : Rockmart  
 Weather : cloudy  
 Departure Time : 04/25/2025 16:00  
 ASEC Technician Name : Aminullah Azimi

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY