

Date : 06/21/2025  
Project No : 2025C160  
Client Company : Artisan  
Arrival Time : 06/21/2025 07:30  
Onsite Hours :

ASEC Report ID : 82436  
Name of the Project : Rockmart Township - 115 Felton Drive  
Project Location : Rockmart  
Weather : Sunny  
Departure Time : 06/21/2025  
ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
06/21/2025	1	18.3	98.3	2025-012 SP	105.6	18.9	93.1	90	D2937	Pass
Location : Lot #168, Elv/Depth :793 Comment : Contractor continued compaction as test was performed. Tested By : Sean Willett										
06/21/2025	2	18.5	97.3	2025-012 SP	105.6	18.9	92.1	90	D2937	Pass
Location : Lot #170, Elv/Depth :793 Comment : Contractor continued compaction as test was performed. May have encountered a new fill material. Transported sample back to our lab. Tested By : Sean Willett										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/21/2025  
Project No : 2025C160  
Client Company : Artisan  
Arrival Time : 06/21/2025 07:30  
Onsite Hours :

ASEC Report ID : 82436  
Name of the Project : Rockmart Township - 115 Felton Drive  
Project Location : Rockmart  
Weather : Sunny  
Departure Time : 06/21/2025  
ASEC Technician Name : Sean Willett

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY