

Date : 06/27/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 06/27/2025 08:30
 Onsite Hours :

ASEC Report ID : 82625
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather : Sunny
 Departure Time : 06/27/2025
 ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
06/27/2025	1	14.5	91.5			0			Check	
Location : Roadway, Elv/Depth :2 feet below finished grade										
Comment : In-situ moisture content test										
Tested By : Sean Willett										
06/27/2025	2	26.4	93.6						Check	
Location : Roadway, Elv/Depth :2 feet below finished grade										
Comment : In-situ moisture content test										
Tested By : Sean Willett										
06/27/2025	6	20.7	97.9			0			Check	
Location : Roadway, Elv/Depth :2 feet below finished grade										
Comment : In-situ moisture content test										
Tested By : Sean Willett										

Remark: Test performed in general accordance with signatored referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/27/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 06/27/2025 08:30
 Onsite Hours :

ASEC Report ID : 82625
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather : Sunny
 Departure Time : 06/27/2025
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY
05/05/2025	2025-025 SP	104.5	13.2	Standard	Light brown sandy silt