

Date : 07/03/2025  
Project No : 2025C160  
Client Company : Artisan  
Arrival Time : 07/03/2025 08:00  
Onsite Hours : 07:30

ASEC Report ID : 82732  
Name of the Project : Rockmart Township - 115 Felton Drive  
Project Location : Rockmart  
Weather : Sunny  
Departure Time : 07/03/2025 15:30  
ASEC Technician Name : Austin Coleman

---

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our representative performed two check plugs on what appeared to be two separate materials that had been placed and compacted on the roadways of the jobsite. The materials were found to be different in color but very similar materials otherwise. We found that the two check plug densities were virtually the same and did not match one of the moisture-density relationships for the project. Roadway testing for compaction began using a field proctor and with the nuclear density gauge. Four (4) roadway tests and 2 tests on Lot #94 were tested. A proof-roll was also performed where 2 to 6 feet of fill had been placed. One soft spot was identified and relayed to the contractor who corrected this area (approximately 4 feet x 7 feet).

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.