

Date : 07/09/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 07/09/2025 10:30
Onsite Hours : 04:00

ASEC Report ID : 82914
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather : Partly cloudy
Departure Time : 07/09/2025 14:30
ASEC Technician Name : Austin Coleman

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
07/09/2025	1	26.6	90.4	Field proctor		0			Check	
Location : Lower lots, Elv/Depth :at finished grade Comment : Tested By : Austin Coleman										
07/09/2025	2	20	92.4	2025-025 SP	104.5	13.2	88.4	95	D6938	Fail
Location : Lower lots (west side), Elv/Depth :3 feet below finished grade Comment : Measured at 95% compaction on the field proctor (possibly a different material) Tested By : Austin Coleman Gauge Serial No. :										
07/09/2025	3	20	93.7	2025-012 SP	105.6	18.9	88.7	95	D6938	Fail
Location : Lower lots (east side), Elv/Depth :3 feet below finished grade Comment : Hit at 95.8% compaction on the field proctor Tested By : Austin Coleman Gauge Serial No. :										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 07/09/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 07/09/2025 10:30
Onsite Hours : 04:00

ASEC Report ID : 82914
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather : Partly cloudy
Departure Time : 07/09/2025 14:30
ASEC Technician Name : Austin Coleman

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY
05/05/2025	2025-025 SP	104.5	13.2	Standard	Light brown sandy silt