

Date : 04/02/2026
 Project No : 2025C186
 Client Company : CWM
 Arrival Time : 04/02/2026
 Onsite Hours : N/A

ASEC Report ID : 92280
 Name of the Project : Tom B. David Airport - Rehab Parallel Taxiway & Terminal Apron
 Project Location : Calhoun
 Weather : overcast
 Departure Time : 04/02/2026
 ASEC Technician Name : Russell Hendrix

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/02/2026	1	3.8	147.6	2025-065	150.1	5.3	98.3	98	D6938	Pass
Location : A3 Taxiway Center, Elv/Depth :Top of subgrade										
Comment :										
Tested By : Russell Hendrix Gauge Serial No. : 38069										
04/02/2026	2	3.5	143.3	2025-065	150.1	5.3	95.5	98	D6938	Fail
Location : A# to A4 connector Center, Elv/Depth :Top of Subgrade										
Comment : UES stated the test result was acceptable										
Tested By : Russell Hendrix Gauge Serial No. : 38069										
04/02/2026	3	3.7	148.2	2025-065	150.1	5.3	98.7	98	D6938	Pass
Location : A4 Taxiway, Elv/Depth :Top of subgrade										
Comment :										
Tested By : Russell Hendrix Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman
Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/02/2026
Project No : 2025C186
Client Company : CWM
Arrival Time : 04/02/2026
Onsite Hours : N/A

ASEC Report ID : 92280
Name of the Project : Tom B. David Airport - Rehab Parallel
Taxiway & Terminal Apron
Project Location : Calhoun
Weather : overcast
Departure Time : 04/02/2026
ASEC Technician Name : Russell Hendrix

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/24/2026	2025-065	150.1	5.3	Modified	Stockpiled GAB for use as base material