


Date : 10/15/2025
Project No : 2025C211
Client Company : Pulte
Arrival Time : 10/15/2025 14:00
Onsite Hours : 03:00

ASEC Report ID : 86967
Name of the Project : Haley's Bluff - Philadelphia Rd.
Project Location : Jasper
Weather : Sunny
Departure Time : 10/15/2025 17:00
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site for the observation/testing of the placement of fill/backfill. Contractors began filling the deceleration lane by the entrance. This area was proof-rolled previously by Mr. Clyde Smith (ASEC). Density testing was performed and test results were provided to the contractor. A field proctor was performed on the material located at the bottom of retention pond (by the deceleration lane). This material appears to be different from the initial sample taken to the lab for a moisture-density relationship (proctor).

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.