

Date : 12/31/2025  
Project No : 2025C211  
Client Company : Pulte  
Arrival Time : 12/31/2025 07:30  
Onsite Hours : 07:30

ASEC Report ID : 88932  
Name of the Project : Haley's Bluff - Philadelphia Rd.  
Project Location : Jasper  
Weather : Sunny  
Departure Time : 12/31/2025 15:00  
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site to observe the contractor (NG Grading) and for the observation/testing of the placement of fill/backfill. The contractor continued placing soil lifts of approximately 8 to 12 inches in size across Lots #14 through #19 area. Lifts were compacted using a sheep-foot roller. Density testing was performed, and test results were provided to the contractor. ASEC watched as loaded off road trucks rolled across the lifts to check for stability.

The wall crew was not on site today.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



8 - 13 and 52 - 60 area



14 - 19 area

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.