

Date : 01/14/2026
 Project No : 2025C211
 Client Company : Pulte
 Arrival Time : 01/14/2026 07:30
 Onsite Hours : 08:00

ASEC Report ID : 89290
 Name of the Project : Haley's Bluff - Philadelphia Rd.
 Project Location : Jasper
 Weather : Sunny
 Departure Time : 01/14/2026 15:30
 ASEC Technician Name : Sean Willett

| Test Date | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|---|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 01/14/2026 | 1 | 21.6 | 97.0 | FP 2 | 100.0 | 18.5 | 97.0 | 98 | D6938 | Fail |
| Location : Pipeline 2.0 to 2.1, Elv/Depth :at finished grade Comment : contractor will recompact again and will retest on a later date Tested By : Sean Willett Gauge Serial No. : 77-19952 | | | | | | | | | | |

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 01/14/2026
 Project No : 2025C211
 Client Company : Pulte
 Arrival Time : 01/14/2026 07:30
 Onsite Hours : 08:00

ASEC Report ID : 89290
 Name of the Project : Haley's Bluff - Philadelphia Rd.
 Project Location : Jasper
 Weather : Sunny
 Departure Time : 01/14/2026 15:30
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

| TEST DATE | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|------------|------------|-----------------------|----------------------|--------------|--|
| 10/13/2025 | 2025-048 | 109.2 | 16.1 | Standard | Red micaceous sandy silt (fine to coarse sand) |
| 10/15/2025 | FP 1 | 95.0 | 22.0 | Standard | Red micaceous silty sand with clay |
| 11/03/2025 | 2025-055 | 107.3 | 15.5 | Standard | Light brown sandy silt |
| 10/31/2025 | FP 2 | 100.0 | 18.5 | Standard | Brown micaceous sandy silt |
| 11/10/2025 | FP 3 | 100.5 | 20.5 | Standard | Red sandy silt with clay |