Daily Field Report

Date : 01/15/2026
Project No : 2025C211
Client Company : Pulte
Arrival Time : 01/15/2026 07:00
Onsite Hours : 9:00

ASEC Report ID : 89282
Name of the Project : Haley's Bluff - Philadelphia Rd.
Project Location : Jasper
Weather : Sunny
Departure Time : 01/15/2026 16:00
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site to observe the contractor (NG Grading) and for the observation/testing of the placement of fill/backfill.

The grading crews continued placement of topsoil along slopes and greenspace areas. The soil lifts were approximately 12 inches in thickness and compacted using a sheep-foot roller.

The pipe crew continued backfilling of sewer pipeline 2.0 to 2.1 located in the roadway by Lot #25. Density testing was performed and test results were provided to the contractor.

The wall crew placed geogrid in the excavated undercut in the footing of retaining wall #5. Then the contractors spread approx. 4 feet of No. 57 stone into the 4-foot undercut section of the wall. They spread approximately 8 to 12 inches of No. 57 stone in the 2-foot undercut location. This was not recommended by ASEC. Upon inspection, ASEC recommended to remove the GAB that was placed and to spread the No. 57 stone as per our original recommendation (2 feet of No. 57 stone with a 6-inch cap of GAB). The contractor argued about how long the wait had been to get started and how it’s not their job to spread the rock out into the footing. Density testing was performed, and test results were provided to the contractor.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.

pipeline

footing

Daily Field Report

Date : 01/15/2026
Project No : 2025C211
Client Company : Pulte
Arrival Time : 01/15/2026 07:00
Onsite Hours : 9:00

ASEC Report ID : 89282
Name of the Project : Haley's Bluff - Philadelphia Rd.
Project Location : Jasper
Weather : Sunny
Departure Time : 01/15/2026 16:00
ASEC Technician Name : Sean Willett

footing

footing

footing

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.