

Date : 04/07/2026  
Project No : 2025C214  
Client Company : Artisan  
Arrival Time : 04/07/2026 07:00  
Onsite Hours : 05:00

ASEC Report ID : 92560  
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 04/07/2026 12:00  
ASEC Technician Name : Clyde Smith


As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative observed concrete placement for the northside bridge abutment A1 footing. ASEC onsite technicians molded six (6) sets of five (5) test cylinders and performed slump, air, unit weight and temperature checks on concrete placement of approximately 300 cubic yards using a 3500 psi mix. The concrete placement location was placed from east side to west side. The writer also continued observing the in-place reinforcing steel prior to concrete placement as referred to site documents in title ABUTMENT A1, Pumpkinvine Creek NatureWalk.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Concrete test cylinders molded



Placement using pump truck

Date : 04/07/2026  
Project No : 2025C214  
Client Company : Artisan  
Arrival Time : 04/07/2026 07:00  
Onsite Hours : 05:00

ASEC Report ID : 92560  
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 04/07/2026 12:00  
ASEC Technician Name : Clyde Smith



Concrete placement by pumping



Concrete sampling and testing by ASEC

Date : 04/07/2026  
Project No : 2025C214  
Client Company : Artisan  
Arrival Time : 04/07/2026 07:00  
Onsite Hours : 05:00

ASEC Report ID : 92560  
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 04/07/2026 12:00  
ASEC Technician Name : Clyde Smith



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.