

Date : 05/29/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 05/29/2026
Onsite Hours : N/A

ASEC Report ID : 95202
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : Sunny
Departure Time : 05/29/2026
ASEC Technician Name : Sean Willett

Location(S): wall for bridge, wall for bridge, wall for bridge, wall for bridge, wall for bridge

Testing: 5 Set of concrete specimens (7 per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

Compliance: Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Specimen Pick Up: 5 Sets of concrete specimens/ 7 specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Specimen were stored for the initial 24 hours
 Near the poured structure
 In an insulated curing box
 Other

Remarks:

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 05/29/2026
 Project No : 2025C214
 Client Company : Artisan
 Arrival Time : 05/29/2026
 Onsite Hours : N/A

ASEC Report ID : 95202
 Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 05/29/2026
 ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: N/A	Laboratory Number: N/A
Date Sampled: 05/29/2026	Time Sampled: 07:06
Sampled By: Sean Willett	Concrete Supplier: Ernest
Contractor: N/A	Mix ID: 40CA6
Truck Number: 474	Quantity of Load: 9
Time Batched: 06:02	Specified Strength: 4000 AEA
Location of Placement: wall for bridge	Concrete Temp (°f): 75
Number of Samples Cast: 7	Air Content (%): 3.5
Ambient Temp (°f): 70	Unit Weight (pcf): 141.6
Slump (in.): 8.5	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
No test results available									

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed

Date : 05/29/2026
 Project No : 2025C214
 Client Company : Artisan
 Arrival Time : 05/29/2026
 Onsite Hours : N/A

ASEC Report ID : 95202
 Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 05/29/2026
 ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: N/A	Laboratory Number: N/A
Date Sampled: 05/29/2026	Time Sampled: 08:13
Sampled By: Sean Willett	Concrete Supplier: Ernest
Contractor: N/A	Mix ID: 40CA6
Truck Number: 490	Quantity of Load: 54
Time Batched: 07:14	Specified Strength: 4000 AEA
Location of Placement: wall for bridge	Concrete Temp (°f): 77
Number of Samples Cast: 7	Air Content (%): 3.0
Ambient Temp (°f): 71	Unit Weight (pcf): 145.6
Slump (in.): 5	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
No test results available									

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed

Date : 05/29/2026
 Project No : 2025C214
 Client Company : Artisan
 Arrival Time : 05/29/2026
 Onsite Hours : N/A

ASEC Report ID : 95202
 Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 05/29/2026
 ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: N/A	Laboratory Number: N/A
Date Sampled: 05/29/2026	Time Sampled: 09:35
Sampled By: Sean Willett	Concrete Supplier: Ernest
Contractor: N/A	Mix ID: 40CA6
Truck Number: 467	Quantity of Load: 126
Time Batched: 08:52	Specified Strength: 4000 AEA
Location of Placement: wall for bridge	Concrete Temp (°f): 76
Number of Samples Cast: 7	Air Content (%): 3.5
Ambient Temp (°f): 72	Unit Weight (pcf): 147.6
Slump (in.): 4.5	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
No test results available									

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed

Date : 05/29/2026
 Project No : 2025C214
 Client Company : Artisan
 Arrival Time : 05/29/2026
 Onsite Hours : N/A

ASEC Report ID : 95202
 Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 05/29/2026
 ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: N/A	Laboratory Number: N/A
Date Sampled: 05/29/2026	Time Sampled: 10:22
Sampled By: Sean Willett	Concrete Supplier: Ernest
Contractor: N/A	Mix ID: 40CA6
Truck Number: 474	Quantity of Load: 153
Time Batched: 09:12	Specified Strength: 4000 AEA
Location of Placement: wall for bridge	Concrete Temp (°f): 77
Number of Samples Cast: 7	Air Content (%): 3.5
Ambient Temp (°f): 75	Unit Weight (pcf): 146.4
Slump (in.): 7.5	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
No test results available									

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed

Date : 05/29/2026
 Project No : 2025C214
 Client Company : Artisan
 Arrival Time : 05/29/2026
 Onsite Hours : N/A

ASEC Report ID : 95202
 Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 05/29/2026
 ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: N/A	Laboratory Number: N/A
Date Sampled: 05/29/2026	Time Sampled: 11:15
Sampled By: Sean Willett	Concrete Supplier: Ernest
Contractor: N/A	Mix ID: 40CA6
Truck Number: 306	Quantity of Load: 207
Time Batched: 10:05	Specified Strength: 4000 AEA
Location of Placement: wall for bridge	Concrete Temp (°f): 80
Number of Samples Cast: 7	Air Content (%): 2.5
Ambient Temp (°f): 76	Unit Weight (pcf): 144.4
Slump (in.): 4.5	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
No test results available									

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed