

Date : 08/14/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 08/14/2025 09:30
Onsite Hours : 06:00

ASEC Report ID : 84331
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : Mostly sunny
Departure Time : 08/14/2025 15:30
ASEC Technician Name : Safiullah Momand

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Construction Activities Monitoring Report

On the mentioned date, the AS Engineering and Consulting LLC engineering representative was on site to observe the construction activities in progress at the project site. The work took place from 09:30 AM until 15:30 PM and included the following activities:

- Backfilling of the sewer line from 2A to 3A.

1. Backfilling of the sewer line from 2A to 3A

Backfill over the sewer line 2A to 3A was in progress. The ASEC technician observed the backfill activates identifying soft areas around the sewer manhole that was point out and recommended for recompaction to the backfilling crew.

2. Equipment in Operation

The following machinery was used for the day's activities:

- 1 smooth drum roller
- 1 small remote-controlled roller

The work progressed smoothly, and all activities were completed without major issues.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.

Date : 08/14/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 08/14/2025 09:30
Onsite Hours : 06:00

ASEC Report ID : 84331
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : Mostly sunny
Departure Time : 08/14/2025 15:30
ASEC Technician Name : Safiullah Momand



Sewer line Backfilling work



Sewer line Backfilling work



Sewer line Backfilling work



Sewer line Backfilling work

Date : 08/14/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 08/14/2025 09:30
Onsite Hours : 06:00

ASEC Report ID : 84331
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : Mostly sunny
Departure Time : 08/14/2025 15:30
ASEC Technician Name : Safiullah Momand



Sewer line Backfilling work



Sewer line Backfilling work



Sewer line Backfilling work



Sewer line Backfilling work

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.