

Date : 08/19/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 08/19/2025 9:00
Onsite Hours : 07:30

ASEC Report ID : 84586
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : sunny
Departure Time : 08/19/2025 16:30
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
08/19/2025	1	23.5	111.9	2025-032 SP	94.9	25.0	95.5	95	D6938	Pass
Location : Between MHB9 and MH9, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 30942										
08/19/2025	2	24.1	90.7	2025-032 SP	94.9	25.0	95.6	95	D6938	Pass
Location : 10 feet to the north of MHB9, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 30942										
08/19/2025	3	22.3	90.7	2025-032 SP	94.9	25.0	95.6	95	D6938	Pass
Location : 12 feet to the south of MH9, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 30942										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 08/19/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 08/19/2025 9:00
Onsite Hours : 07:30

ASEC Report ID : 84586
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : sunny
Departure Time : 08/19/2025 16:30
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/28/2025	2025-031 SP	101.0	20.7	Standard	Tan, brown Micaceous Sandy SILT
07/28/2025	2025-032 SP	94.9	25.0	Standard	Red Micaceous Sandy CLAY
08/01/2025	2025-033 SP	104.0	16.2	Standard	Tan, brown, micaceous Sandy SILT