


Date : 09/09/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 09/09/2025 08:00
Onsite Hours : 9:00

ASEC Report ID : 86375
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : Sunny
Departure Time : 09/09/2025 17:00
ASEC Technician Name : Austin Coleman

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our representative began with a check plug to identify the proctor of the soil. Density testing was then performed using a nuclear density gauge. All density tests met job specifications for compaction.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Date : 09/09/2025
Project No : 2025C215
Client Company : Artisan
Arrival Time : 09/09/2025 08:00
Onsite Hours : 9:00

ASEC Report ID : 86375
Name of the Project : NW Unit 4 Parkway Ext. Phase 1
Project Location : Dallas
Weather : Sunny
Departure Time : 09/09/2025 17:00
ASEC Technician Name : Austin Coleman



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.