

Date : 09/09/2025  
Project No : 2025C215  
Client Company : Artisan  
Arrival Time : 09/09/2025 08:00  
Onsite Hours : 07:30

ASEC Report ID : 86672

Name of the Project : NW Unit 4 Parkway Ext. Phase 1

Project Location : Dallas

Weather : Sunny

Departure Time : 09/09/2025 15:30

ASEC Technician Name : Austin Coleman

| Test Date                                                                                                                                            | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 09/09/2025                                                                                                                                           | 1           | 15.3                 | 98.0              |                |                        |                      |                |                          | Check            |           |
| Location : Cul de sac, Elv/Depth :<br>Comment : 102 pcf maximum dry density and 15.0 percent optimum moisture content.<br>Tested By : Austin Coleman |             |                      |                   |                |                        |                      |                |                          |                  |           |

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/09/2025  
Project No : 2025C215  
Client Company : Artisan  
Arrival Time : 09/09/2025 08:00  
Onsite Hours : 07:30

ASEC Report ID : 86672  
Name of the Project : NW Unit 4 Parkway Ext. Phase 1  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 09/09/2025 15:30  
ASEC Technician Name : Austin Coleman

---

**PROCTOR DATA SUMMARY**

| TEST DATE  | PROCTOR ID  | MAX DRY<br>DENSITY (pcf) | OPTIMUM<br>MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION                 |
|------------|-------------|--------------------------|-------------------------|--------------|----------------------------------|
| 07/28/2025 | 2025-031 SP | 101.0                    | 20.7                    | Standard     | Tan, brown Micaceous Sandy SILT  |
| 07/28/2025 | 2025-032 SP | 94.9                     | 25.0                    | Standard     | Red Micaceous Sandy CLAY         |
| 08/01/2025 | 2025-033 SP | 104.0                    | 16.2                    | Standard     | Tan, brown, micaceous Sandy SILT |