

Date : 02/17/2026  
 Project No : 2025C215  
 Client Company : Artisan  
 Arrival Time : 02/17/2026 09:00  
 Onsite Hours : 9:00

ASEC Report ID : 90355  
 Name of the Project : NW Unit 4 Parkway Ext. Phase 1  
 Project Location : Dallas  
 Weather : sunny  
 Departure Time : 02/17/2026 18:00  
 ASEC Technician Name : Clyde Smith

| Test Date   | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|---|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 02/17/2026  | 1           | 13.3                 | 103.4             | 2025-035<br>SP | 107.8                  | 13.0                 | 95.9           | 95                       | D6938            | Pass      |
| Location : 18" RCP storm line between D13 and D20, Elv/Depth :4 feet below finished grade |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :   |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Clyde Smith Gauge Serial No. : 91643  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 02/17/2026  | 2           | 12.8                 | 104.8             | 2025-035<br>SP | 107.8                  | 13.0                 | 97.2           | 95                       | D6938            | Pass      |
| Location : 18" RCP storm line between D13 and D20, Elv/Depth :4 feet below finished grade |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :   |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Clyde Smith Gauge Serial No. : 91643  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 02/17/2026  | 3           | 12.1                 | 118.7             | 2025-035<br>SP | 107.8                  | 13.0                 | 98.2           | 95                       | D6938            | Pass      |
| Location : 18" RCP storm line between D13 and D20, Elv/Depth :2 feet below finished grade |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :   |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Clyde Smith Gauge Serial No. : 91643  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 02/17/2026  | 4           | 14.2                 | 120.9             | 2025-035<br>SP | 107.8                  | 13.0                 | 98.2           | 95                       | D6938            | Pass      |
| Location : 18" RCP storm line between D13 and D20, Elv/Depth :2 feet below finished grade |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :   |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Clyde Smith Gauge Serial No. : 91643  |             |                      |                   |                |                        |                      |                |                          |                  |           |

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/17/2026  
 Project No : 2025C215  
 Client Company : Artisan  
 Arrival Time : 02/17/2026 09:00  
 Onsite Hours : 9:00

ASEC Report ID : 90355  
 Name of the Project : NW Unit 4 Parkway Ext. Phase 1  
 Project Location : Dallas  
 Weather : sunny  
 Departure Time : 02/17/2026 18:00  
 ASEC Technician Name : Clyde Smith

**PROCTOR DATA SUMMARY**

| TEST DATE  | PROCTOR ID       | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION                 |
|------------|------------------|-----------------------|----------------------|--------------|----------------------------------|
| 07/28/2025 | 2025-031 SP      | 101.0                 | 20.7                 | Standard     | Tan, brown Micaceous Sandy SILT  |
| 07/28/2025 | 2025-032 SP      | 94.9                  | 25.0                 | Standard     | Red Micaceous Sandy CLAY         |
| 08/01/2025 | 2025-033 SP      | 104.0                 | 16.2                 | Standard     | Tan, brown, micaceous Sandy SILT |
| 08/14/2025 | 2025-035 SP      | 107.8                 | 13.0                 | Standard     | Red sandy silt                   |
| 08/14/2025 | 2025-036 SP      | 107.0                 | 18.5                 | Standard     | Red micaceous sandy silt         |
| 01/30/2026 | Field proctor #6 | 98.0                  | 17.2                 | Standard     | Multi-colored sandy SILT         |