

Date : 09/29/2025
 Project No : 2025C216
 Client Company : Artisan
 Arrival Time : 09/29/2025
 Onsite Hours : N/A

ASEC Report ID : 86626
 Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 09/29/2025
 ASEC Technician Name : Sean Willett

| Test Date | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|--|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 09/29/2025 | 1 | 13.5 | 102.1 | 2025-036 SP | 107.0 | 18.5 | 95.4 | 95 | D6938 | Pass |
| Location : SSMH B2, Elv/Depth :at finished grade | | | | | | | | | | |
| Comment : | | | | | | | | | | |
| Tested By : Sean Willett Gauge Serial No. : 77-19952 | | | | | | | | | | |
| 09/29/2025 | 2 | 13.3 | 102.1 | 2025-036 SP | 107.0 | 18.5 | 95.4 | 95 | D6938 | Pass |
| Location : SSMH B2, Elv/Depth :at finished grade | | | | | | | | | | |
| Comment : | | | | | | | | | | |
| Tested By : Sean Willett Gauge Serial No. : 77-19952 | | | | | | | | | | |
| 09/29/2025 | 3 | 17 | 103.8 | 2025-036 SP | 107.0 | 18.5 | 97.0 | 95 | D6938 | Pass |
| Location : SSMH B3, Elv/Depth :at finished grade | | | | | | | | | | |
| Comment : | | | | | | | | | | |
| Tested By : Sean Willett Gauge Serial No. : 77-19952 | | | | | | | | | | |

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/29/2025
 Project No : 2025C216
 Client Company : Artisan
 Arrival Time : 09/29/2025
 Onsite Hours : N/A

ASEC Report ID : 86626
 Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 09/29/2025
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

| TEST DATE | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|------------|-------------|-----------------------|----------------------|--------------|---------------------------------|
| 07/28/2025 | 2025-031 SP | 101.0 | 20.7 | Standard | Tan, brown micaceous sandy silt |
| 07/28/2025 | 2025-032 SP | 94.9 | 25.0 | Standard | Red micaceous sandy clay |
| 08/01/2025 | 2025-033 SP | 104.0 | 16.2 | Standard | Tan, brown micaceous sandy silt |
| 08/14/2025 | 2025-035 SP | 107.8 | 13.0 | Standard | Red sandy silt |
| 08/14/2025 | 2025-036 SP | 107.0 | 18.5 | Standard | Red micaceous sandy silt |