

Date : 12/22/2025
Project No : 2025C216
Client Company : Artisan
Arrival Time : 12/22/2025 09:00
Onsite Hours : 05:00

ASEC Report ID : 88771
Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
Project Location : Dallas
Weather : cloudy
Departure Time : 12/22/2025 14:00
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the pipe contractor continue installing 8" PVC sanitary sewer line between manholes #11 and 12. The pipe was bedded on No. #57 stone, and the sides were also backfilled with No. #57 stone. The writer performed density tests between manhole structures #10, 11 and 12 using a Troxler nuclear gauge model 3440 serial no.91643. Compaction results were in compliance with job specifications.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



8" sanitary sewer pipe installation backfill and testing



Date : 12/22/2025
Project No : 2025C216
Client Company : Artisan
Arrival Time : 12/22/2025 09:00
Onsite Hours : 05:00

ASEC Report ID : 88771
Name of the Project : NW (Lots) Unit 4 PH 1A & 1B
Project Location : Dallas
Weather : cloudy
Departure Time : 12/22/2025 14:00
ASEC Technician Name : Clyde Smith



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.