

## **Daily Field Report**

Date: 10/17/2025 ASEC Report ID: 87129 Project No: 2025C224

Name of the Project: PDK Airport - RUNWAY 3R-21L KEEL REPLACEMENT

Client Company: C. W. MATTHEWS CONTRACTING CO., INC. Project Location: PDK AIRPORT, DEKALB County, GA Arrival Time: 10/17/2025 Onsite Hours: N/A Weather: sunny

Departure Time: 10/17/2025

ASEC Technician Name: Russell Hendrix

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals.

At the request of Brad from C.W. Matthews, ASEC was asked to perform density testing on the finished grade of recycled concrete that had been placed and compacted on the Alpha ramp. It was noted that the placement activities were not observed by ASEC personnel.

Two (2) nuclear density tests were performed using a Troxler 3430 gauge (Serial #38069). Both tests yielded compaction results of 97%, which do not meet the project requirement of 100% compaction.


Test results were provided to C.W. Matthews on site at the time of testing. No remediation efforts were observed or reported following the test failures.

## **Additional Notes:**

No further observations were made during the visit.



Alpha ramp with recycled concrete placed



Alpha ramp with recycled concrete placed



## **Daily Field Report**

Date : 10/17/2025 Project No : 2025C224

Client Company: C. W. MATTHEWS CONTRACTING CO., INC.

Arrival Time: 10/17/2025 Onsite Hours: N/A  $\begin{array}{c} {\rm ASEC\ Report\ ID:87129} \\ {\rm Name\ of\ the\ Project:PDK\ Airport-RUNWAY\ 3R-21L\ KEEL} \\ {\rm REPLACEMENT} \end{array}$ 

Project Location : PDK AIRPORT, DEKALB County, GA Weather : sunny

Departure Time: 10/17/2025

ASEC Technician Name : Russell Hendrix



testing

Kenneth Mosman

<u>Kenneth Mosman</u>

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.