

Date : 01/17/2026  
Project No : 2025C244  
Client Company : McCallan Group  
Arrival Time : 01/17/2026 8:00  
Onsite Hours : 07:00

ASEC Report ID : 89537  
Name of the Project : Cassville Rd tract, proposed Burrito  
Wrap  
Project Location : Cartersville  
Weather : cold  
Departure Time : 01/17/2026 15:00  
ASEC Technician Name : Mahendra Mylabathula

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

The crew continued soil excavation from the pond area and placed the material as backfill in Lots #42, 26, and 25. The placed soil was spread achieve the required elevation in accordance with the site grading plan.

Field density testing indicated the moisture contents of the backfill material were slightly higher than optimum; however, the contractor proceeded with placement and compaction operations. The ground surface was subsequently fine graded and compacted to complete the backfilling activities on the designated lots.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.