

Date : 10/04/2025
Project No : 2025C245
Client Company : Bearing Engineering
Arrival Time : 10/04/2025 08:00
Onsite Hours : 01:00

ASEC Report ID : 86646
Name of the Project : Dunkin Donuts 2025
Project Location : US 29, Palmetto, GA
Weather : Overcast
Departure Time : 10/04/2025 09:00
ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/04/2025	1	20.6	0.0						Check	
Location : moisture check on stockpile, Elv/Depth :0										
Comment : Too high for lab proctor 115.6 @ 12.7%										
Tested By : Sean Willett										
10/04/2025	2	21.1	0.0						Check	
Location : Moisture check on stockpile, Elv/Depth :0										
Comment : Contractor informed this material is within optimum moisture for proctor of 103.6 @ 17.1%										
Tested By : Sean Willett										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 10/04/2025
Project No : 2025C245
Client Company : Bearing Engineering
Arrival Time : 10/04/2025 08:00
Onsite Hours : 01:00

ASEC Report ID : 86646
Name of the Project : Dunkin Donuts 2025
Project Location : US 29, Palmetto, GA
Weather : Overcast
Departure Time : 10/04/2025 09:00
ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/03/2025	2025-041	115.6	12.7	Standard	Tan and Brown Silty Sand w/clay and rock fragments
10/03/2025	2	103.6	17.1	Standard	Brown sandy silt
10/03/2025	3	94.7	25.3	Standard	Red silty sand