

Date : 12/22/2025  
Project No : 2025C260  
Client Company : Artisan  
Arrival Time : 12/22/2025 14:00  
Onsite Hours : 02:00

ASEC Report ID : 88777  
Name of the Project : NW (PHASE 2) Parkway Extension  
Project Location : Dallas  
Weather : cloudy  
Departure Time : 12/22/2025 16:00  
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the grading contractor continue to place fill for the cul de sac building lots. The fill materials were placed in compacted lifts and density tests were performed using a Troxler nuclear gauge model 3430, serial no. 91643. The fill placement was observed and tested at elevations 866.00 and 863.00. Compaction results were in compliance with job specifications.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Fill placement at cul de sac lots and density tests



Date : 12/22/2025  
Project No : 2025C260  
Client Company : Artisan  
Arrival Time : 12/22/2025 14:00  
Onsite Hours : 02:00

ASEC Report ID : 88777  
Name of the Project : NW (PHASE 2) Parkway Extension  
Project Location : Dallas  
Weather : cloudy  
Departure Time : 12/22/2025 16:00  
ASEC Technician Name : Clyde Smith



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.