

Date : 12/29/2025  
Project No : 2025C260  
Client Company : Artisan  
Arrival Time : 12/29/2025 10:00  
Onsite Hours : 06:00

ASEC Report ID : 88901  
Name of the Project : NW (PHASE 2) Parkway Extension  
Project Location : Dallas  
Weather : cloudy  
Departure Time : 12/29/2025 16:00  
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the grading contractor continue placing fill for the cul de sac basement lots. The writer performed density tests using a Troxler nuclear gauge model 3430, serial no. 91643. Compaction results were in compliance with job specifications and observed at elevations 873, 872, 871, 869 and 870.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Performing density tests at cul de sac basement lots

Date : 12/29/2025  
Project No : 2025C260  
Client Company : Artisan  
Arrival Time : 12/29/2025 10:00  
Onsite Hours : 06:00

ASEC Report ID : 88901  
Name of the Project : NW (PHASE 2) Parkway Extension  
Project Location : Dallas  
Weather : cloudy  
Departure Time : 12/29/2025 16:00  
ASEC Technician Name : Clyde Smith



Slope grading and stabilization at Nature Walk parkway



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.