

Date : 01/08/2026
 Project No : 2025C260
 Client Company : Artisan
 Arrival Time : 01/08/2026 08:00
 Onsite Hours : 9:00

ASEC Report ID : 89041
 Name of the Project : NW (PHASE 2) Parkway Extension
 Project Location : Dallas
 Weather : cloudy
 Departure Time : 01/08/2026 17:00
 ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
01/08/2026	1	13.3	102.7	2025-035 SP	107.8	13.0	95.3	95	D6938	Pass
Location : Building lots at cul-de-sac, Elv/Depth :881										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										
01/08/2026	2	11.5	103.2	2025-035 SP	107.8	13.0	95.7	95	D6938	Pass
Location : Building lots at cul-de-sac, Elv/Depth :883										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										
01/08/2026	3	12.2	103.3	2025-035 SP	107.8	13.0	95.8	95	D6938	Pass
Location : Building lots at cul-de-sac, Elv/Depth :885										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 01/08/2026
 Project No : 2025C260
 Client Company : Artisan
 Arrival Time : 01/08/2026 08:00
 Onsite Hours : 9:00

ASEC Report ID : 89041
 Name of the Project : NW (PHASE 2) Parkway Extension
 Project Location : Dallas
 Weather : cloudy
 Departure Time : 01/08/2026 17:00
 ASEC Technician Name : Clyde Smith

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/28/2025	2025-031 SP	101.0	20.7	Standard	Tan, brown micaceous sandy silt
07/28/2025	2025-032 SP	94.9	25.0	Standard	Red micaceous sandy clay
08/01/2025	2025-033 SP	104.0	16.2	Standard	Tan, brown micaceous sandy silt
08/14/2025	2025-035 SP	107.8	13.0	Standard	Red sandy silt
08/14/2025	2025-036 SP	107.0	18.5	Standard	2025-036 SP