

Date : 02/25/2026  
 Project No : 2025C269  
 Client Company : Lewis Contracting  
 Arrival Time : 13:00  
 Onsite Hours : N/A

ASEC Report ID : 90725  
 Name of the Project : Main St. & First Ave. - Mixed-use  
 Project Location : Lilburn  
 Weather : Partly Cloudy  
 Departure Time : 17:00  
 ASEC Technician Name : Jamiries Johnson

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
02/25/2026	1	19.7	85.1	2025-059	88.7	22.0	95.9	95	D2937	Pass
Location : S3-S2, Elv/Depth :3 feet below finished grade Comment : Tested By : Jamiries Johnson										
02/25/2026	2	20.8	92.5	2025-058	95.2	18.6	97.2	95	D2937	Pass
Location : A1-G1, Elv/Depth :3 feet below finished grade Comment : Tested By : Jamiries Johnson										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/25/2026  
 Project No : 2025C269  
 Client Company : Lewis Contracting  
 Arrival Time : 13:00  
 Onsite Hours : N/A

ASEC Report ID : 90725  
 Name of the Project : Main St. & First Ave. - Mixed-use  
 Project Location : Lilburn  
 Weather : Partly Cloudy  
 Departure Time : 17:00  
 ASEC Technician Name : Jamiries Johnson

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
11/21/2025	2025-057	92.1	25.7	Standard	Red Brown Sandy SILT with clay
11/21/2025	2025-058	95.2	18.6	Standard	Tan Brown Sandy SILT
11/21/2025	2025-059	88.7	22.0	Standard	Light Brown Sandy SILT with clay
01/22/2026	2026-010	98.1	22.4	Standard	Brown Sandy SILT
02/11/2026	2026-016	137.4	7.0	Standard	Graded Aggregate Base