

Date : 11/20/2025  
Project No : 2025C269  
Client Company : Lewis Contracting  
Arrival Time : 11/20/2025 14:00  
Onsite Hours : 03:00

ASEC Report ID : 88065  
Name of the Project : Mixed-Use @ Main St. & First Ave.  
Project Location : Lilburn  
Weather : Sunny  
Departure Time : 11/20/2025 17:00  
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to obtain proctor samples. Three bag samples were obtained and transported to our lab to perform a moisture density relationship (proctor). Proctor sample #1 was obtained from the center of the site/west side from an excavation to a depth of -6' and sample #2 and #3 was obtained from the southwest corner of the site from the underground detention area. Sample #2 was mixed from 0' to -6' and #3 was obtained from -6' to -8' and in-situ moisture contents appear to be above optimum.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Obtaining proctor samples #2 and 3 at SW corner of site



Date : 11/20/2025  
Project No : 2025C269  
Client Company : Lewis Contracting  
Arrival Time : 11/20/2025 14:00  
Onsite Hours : 03:00

ASEC Report ID : 88065  
Name of the Project : Mixed-Use @ Main St. & First Ave.  
Project Location : Lilburn  
Weather : Sunny  
Departure Time : 11/20/2025 17:00  
ASEC Technician Name : Clyde Smith



Obtaining proctor sample #1 at west side of site



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.