

Date : 01/06/2026  
 Project No : 2025C281  
 Client Company : SR Homes  
 Arrival Time : 01/06/2026 09:00  
 Onsite Hours : 08:00

ASEC Report ID : 89048  
 Name of the Project : Owen Mills - Owens Store Rd  
 Project Location : Canton  
 Weather : cloudy  
 Departure Time : 01/06/2026 17:00  
 ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
01/06/2026	1	13.7	105.0	2026-002 (on-site cut)	108.9	15.8	96.4	90	D6938	Pass
Location : West side embankment dam, Elv/Depth :1137										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										
01/06/2026	2	14.3	106.0	2026-002 (on-site cut)	108.9	15.8	97.3	90	D6938	Pass
Location : West side embankment dam, Elv/Depth :1138										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										
01/06/2026	3	13.7	106.2	2026-002 (on-site cut)	108.9	15.8	97.5	90	D6938	Pass
Location : West side embankment dam, Elv/Depth :1138										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 91643										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Ramchandra R. Mogulla**  
 GA P.E. 036021  
 Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 01/06/2026  
 Project No : 2025C281  
 Client Company : SR Homes  
 Arrival Time : 01/06/2026 09:00  
 Onsite Hours : 08:00

ASEC Report ID : 89048  
 Name of the Project : Owen Mills - Owens Store Rd  
 Project Location : Canton  
 Weather : cloudy  
 Departure Time : 01/06/2026 17:00  
 ASEC Technician Name : Clyde Smith

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
12/16/2025	2025-052 (off-site stockpile)	101.1	22.6	Standard	Brown Sandy SILT
01/09/2026	2026-002 (on-site cut)	108.9	15.8	Standard	Red micaceous Silty SAND
01/13/2026	2026-001 (on site cut)	99.1	20.1	Standard	Red fine to medium Silty SAND