Daily Field Report

Date : 01/07/2026
Project No : 2025C281
Client Company : SR Homes
Arrival Time : 01/07/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 89563
Name of the Project : Owen Mills - Owens Store Rd
Project Location : Canton
Weather : cold
Departure Time : 01/07/2026 17:
ASEC Technician Name : Mahendra Mylabathula

FIELD OBSERVATIONS

On the above date, an AS Engineering and Consulting, LLC (ASEC) representative visited the site at the contractor's request to **observe earthwork operations and perform quality control testing** associated with the proposed **detention pond construction**.

The contractor performed **partial earthwork operations** on this date. Soil material generated from **nearby tree-clearing activities** was transported to the work area and reused as **backfill behind the proposed wall location**. The material appeared to consist of soil free of visible organic matter or deleterious materials and was considered **acceptable for reuse** based on visual observation.

Backfill was **placed in controlled lifts**, spread uniformly, and **moisture conditioned** prior to compaction. Due to cold weather conditions, the in-place moisture content was observed to be **slightly above laboratory optimum**; however, it remained within an **acceptable range for compaction**. Compaction was performed using a **sheepsfoot roller in conjunction with tracked equipment (dozer)**.

TESTING AND RESULTS

Field **in-place density and compaction testing** was performed on the completed lifts. All test results **met the project specifications** at the time of observation.

Earthwork operations were limited to **partial lift placement only** on this date. Work was suspended at the end of the day, with **additional lift placement and grading to be completed during subsequent workdays**.

Daily Field Report

Date : 01/07/2026
Project No : 2025C281
Client Company : SR Homes
Arrival Time : 01/07/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 89563
Name of the Project : Owen Mills - Owens Store Rd
Project Location : Canton
Weather : cold
Departure Time : 01/07/2026 17:
ASEC Technician Name : Mahendra Mylabathula

Daily Field Report

Date : 01/07/2026
Project No : 2025C281
Client Company : SR Homes
Arrival Time : 01/07/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 89563
Name of the Project : Owen Mills - Owens Store Rd
Project Location : Canton
Weather : cold
Departure Time : 01/07/2026 17:
ASEC Technician Name : Mahendra Mylabathula

Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.