

Date : 02/17/2026
 Project No : 2025C281
 Client Company : SR Homes
 Arrival Time : 02/17/2026 10:00
 Onsite Hours : 08:00

ASEC Report ID : 90805
 Name of the Project : Owen Mills - Owens Store Rd
 Project Location : Canton
 Weather : sunny
 Departure Time : 02/17/2026 18:00
 ASEC Technician Name : Mahendra Mylabathula

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
02/17/2026	1	21.9	98.9	2026-001 (on site cut)	99.1	20.1	99.8	95	D6938	Pass
Location : Roadway near Lots #25 through 31, Elv/Depth :5 feet below finished grade										
Comment :										
Tested By : Mahendra Mylabathula Gauge Serial No. : 38069										
02/17/2026	2	16.4	101.7	2025-052 (off-site stockpile)	101.1	22.6	100.6	95	D6938	Pass
Location : Roadway near Lots #25 through 31, Elv/Depth :5 feet below finished grade										
Comment :										
Tested By : Mahendra Mylabathula Gauge Serial No. : 38069										
02/17/2026	3	16	94.2	2026-001 (on site cut)	99.1	20.1	95.1	95	D6938	Pass
Location : Roadway near Lots #25 through 31, Elv/Depth :6 feet below finished grade										
Comment :										
Tested By : Mahendra Mylabathula Gauge Serial No. :										
02/17/2026	4	18.5	101.2	2025-052 (off-site stockpile)	101.1	22.6	100.1	95	D6938	Pass
Location : Roadway near Lots #25 through 31, Elv/Depth :6 feet below finished grade										
Comment :										
Tested By : Mahendra Mylabathula Gauge Serial No. :										
02/17/2026	5	19.4	102.3	2025-052 (off-site stockpile)	101.1	22.6	101.2	95	D6938	Pass
Location : Roadway near Lots #25 through 31, Elv/Depth :5 feet below finished grade										
Comment :										
Tested By : Mahendra Mylabathula Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/17/2026
 Project No : 2025C281
 Client Company : SR Homes
 Arrival Time : 02/17/2026 10:00
 Onsite Hours : 08:00

ASEC Report ID : 90805
 Name of the Project : Owen Mills - Owens Store Rd
 Project Location : Canton
 Weather : sunny
 Departure Time : 02/17/2026 18:00
 ASEC Technician Name : Mahendra Mylabathula

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
12/16/2025	2025-052 (off-site stockpile)	101.1	22.6	Standard	Brown Sandy SILT
01/09/2026	2026-002 (on-site cut)	108.9	15.8	Standard	Red micaceous Silty SAND
01/13/2026	2026-001 (on site cut)	99.1	20.1	Standard	Red fine to medium Silty SAND