

Date : 04/10/2026
Project No : 2026C101
Client Company : Artisan
Arrival Time : 04/10/2026 13:00
Onsite Hours : 04:00

ASEC Report ID : 92802
Name of the Project : Seven Hills PHASE 13, UNIT 4 Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 04/10/2026 17:00
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the pipe contractor continue backfilling 36" RCP storm line at the on site pond OCS. The contractor also began hauling off organic debris materials excavated to install the pipeline between E o and E 1.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Hauling off excavated organic debris materials



Backfill at OCS storm line



Date : 04/10/2026
Project No : 2026C101
Client Company : Artisan
Arrival Time : 04/10/2026 13:00
Onsite Hours : 04:00

ASEC Report ID : 92802
Name of the Project : Seven Hills PHASE 13, UNIT 4 Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 04/10/2026 17:00
ASEC Technician Name : Clyde Smith



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.