

Date : 04/17/2026
Project No : 2026C101
Client Company : Artisan
Arrival Time : 04/17/2026 08:00
Onsite Hours : 06:00

ASEC Report ID : 93024
Name of the Project : Seven Hills PHASE 13, UNIT 4 Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 04/17/2026 14:00
ASEC Technician Name : Clyde Smith

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date our representative was on site to observe the pipe contractor continue backfilling and completing OCS installation. The backfill observation over the 36" RCP storm line was completed and appeared to be in compliance with site compaction requirements. The contractor continued installation of the OCS.

The pipe contractor performing the directional boring tap in for the water line encountered hard rock within the last fifteen feet today.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Rip Rap place at OCS headwall structure



Completed backfill at dam embankment

Date : 04/17/2026
Project No : 2026C101
Client Company : Artisan
Arrival Time : 04/17/2026 08:00
Onsite Hours : 06:00

ASEC Report ID : 93024
Name of the Project : Seven Hills PHASE 13, UNIT 4 Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 04/17/2026 14:00
ASEC Technician Name : Clyde Smith



Pouring concrete base for trash rack



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.