

Date : 02/12/2026
Project No : 2026C103
Client Company : Artisan
Arrival Time : 02/12/2026 10:30
Onsite Hours : 04:30

ASEC Report ID : 90474
Name of the Project : NW PH 2, UNIT 4
Project Location : Dallas
Weather : Sunny
Departure Time : 02/12/2026 15:00
ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
02/12/2026	1	9.9	98.8	2025-033 SP	104.0	16.2	95.0	95	D6938	Fail
Location : Lot #63, Elv/Depth :897										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	2	7.3	100.2	2025-033 SP	104.0	16.2	96.3	95	D6938	Pass
Location : Lot #64, Elv/Depth :897										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	3	8.9	104.7	2025-033 SP	104.0	16.2	100.7	95	D6938	Pass
Location : Lot #65, Elv/Depth :897										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	4	15.4	82.9	2025-031SP	101.0	20.7	82.1	95	D6938	Fail
Location : Lot #56, Elv/Depth :880										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	5	11.1	97.4	2025-031SP	101.0	20.7	96.4	95	D6938	Pass
Location : Lot #57, Elv/Depth :880										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	6	10.2	91.7	2025-031SP	101.0	20.7	90.8	95	D6938	Fail
Location : Lot #58, Elv/Depth :880										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	7	9.1	89.9	2025-031SP	101.0	20.7	89.0	95	D6938	Fail
Location : Lot #59, Elv/Depth :880										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	8	8.4	93.4	2025-031SP	101.0	20.7	92.5	95	D6938	Fail
Location : Lot #60, Elv/Depth :880										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	9	27.1	96.1	2025-032 SP	94.9	25.0	101.3	98	D6938	Pass
Location : OCS headwall #3, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	10	25.7	95.2	2025-032 SP	94.9	25.0	100.3	98	D6938	Pass
Location : OCS headwall #3, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
02/12/2026	11	24.5	96.9	2025-032 SP	94.9	25.0	102.1	98	D6938	Pass
Location : OCS headwall #3, Elv/Depth :at finished grade										

Date : 02/12/2026
 Project No : 2026C103
 Client Company : Artisan
 Arrival Time : 02/12/2026 10:30
 Onsite Hours : 04:30

ASEC Report ID : 90474
 Name of the Project : NW PH 2, UNIT 4
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 02/12/2026 15:00
 ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
Comment :										
Tested By :				Sean Willett			Gauge Serial No. : 77-19952			

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/12/2026
 Project No : 2026C103
 Client Company : Artisan
 Arrival Time : 02/12/2026 10:30
 Onsite Hours : 04:30

ASEC Report ID : 90474
 Name of the Project : NW PH 2, UNIT 4
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 02/12/2026 15:00
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/28/2025	2025-031SP	101.0	20.7	Standard	Tan, brown micaceous sandy SILT
07/28/2025	2025-032 SP	94.9	25.0	Standard	Red micaceous sandy CLAY
08/01/2025	2025-033 SP	104.0	16.2	Standard	Tan, brown micaceous sandy SILT
08/14/2025	2025-035 SP	107.8	13.0	Standard	Red sandy SILT
08/14/2025	2025-036 SP	107.0	18.5	Standard	Red micaceous sandy SILT
01/30/2026	Field proctor #6	98.0	17.2	Standard	Multi-colored sandy SILT