

Date : 04/25/2026
 Project No : 2026C103
 Client Company : Artisan
 Arrival Time : 04/24/2026 08:00
 Onsite Hours : 03:00

ASEC Report ID : 93542
 Name of the Project : NW PH 2, UNIT 4
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 04/24/2026 11:00
 ASEC Technician Name : Sean Willett

| Test Date | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|-------------------------------------------------------------------------------------------------------------------|-------------|----------------------|-------------------|------------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 04/24/2026 | 1 | 10.4 | 98.7 | Field proctor #6 | 98.0 | 17.2 | 100.7 | 95 | D6938 | Pass |
| Location : B-15, Elv/Depth :4 feet over pipe Comment : Tested By : Sean Willett Gauge Serial No. : 77-19952 | | | | | | | | | | |

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/25/2026
 Project No : 2026C103
 Client Company : Artisan
 Arrival Time : 04/24/2026 08:00
 Onsite Hours : 03:00

ASEC Report ID : 93542
 Name of the Project : NW PH 2, UNIT 4
 Project Location : Dallas
 Weather : Sunny
 Departure Time : 04/24/2026 11:00
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

| TEST DATE | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|------------|------------------|-----------------------|----------------------|--------------|---------------------------------|
| 07/28/2025 | 2025-031SP | 101.0 | 20.7 | Standard | Tan, brown micaceous sandy SILT |
| 07/28/2025 | 2025-032 SP | 94.9 | 25.0 | Standard | Red micaceous sandy CLAY |
| 08/01/2025 | 2025-033 SP | 104.0 | 16.2 | Standard | Tan, brown micaceous sandy SILT |
| 08/14/2025 | 2025-035 SP | 107.8 | 13.0 | Standard | Red sandy SILT |
| 08/14/2025 | 2025-036 SP | 107.0 | 18.5 | Standard | Red micaceous sandy SILT |
| 01/30/2026 | Field proctor #6 | 98.0 | 17.2 | Standard | Multi-colored sandy SILT |