

Date : 06/06/2026  
Project No : 2026C115-WO 1  
Client Company : WSP  
Arrival Time : 06/06/2026 4  
Onsite Hours : NaN:00

ASEC Report ID : 95375  
Name of the Project : Lanier Islands Parkway  
Project Location : Buford  
Weather : clear and sunny  
Departure Time : 06/06/2026 11:30  
ASEC Technician Name : Narayana Ganesh Undavalli

---

**Location(S):**

**Testing:** 2 Set of concrete specimens (5 per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

**Compliance:**  Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)  
 Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

**Specimen Pick Up:** 2 Sets of concrete specimens/ 5 specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

**Field Curing:** Specimen were stored for the initial 24 hours  
 Near the poured structure  
 In an insulated curing box  
 Other

**Remarks:** TEST -1 - Poured at panel A-22 At 10 yds time = 5:05 Am concrete temperature = 80 ambient temperature = 62 slump = 6 Air = 1.7 unit wt of concrete = 146. Test -2 - Poured at panel 13-19 At 110 yds concrete temperature = 880 ambient temperature = 65 slump = 6 Air = 1.5 unit wt of concrete = 144.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.