

Date : 03/31/2026
Project No : 2026C125
Client Company : Lewis Contracting
Arrival Time : 03/31/2026 15:00
Onsite Hours : 01:00

ASEC Report ID : 92526
Name of the Project : Pittman Park - Garibaldi St. Stormwater
Project Location : Atlanta
Weather : Sunny
Departure Time : 03/31/2026 16:00
ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/31/2026	1	20.6	103.5	Proctor 1	104.9	19.8	98.7	95	D6938	Pass
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	2	21.5	104.0	Proctor 1	104.9	19.8	99.1	95	D6938	Pass
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	3	27.9	94.4	Proctor 1	104.9	19.8	90.0	95	D6938	Fail
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	4	21.3	96.2	Proctor 1	104.9	19.8	91.7	95	D6938	Fail
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	5	20.4	105.2	Proctor 1	104.9	19.8	100.3	95	D6938	Pass
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	6	24.1	96.9	Proctor 1	104.9	19.8	92.4	95	D6938	Fail
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	7	22.3	95.2	Proctor 1	104.9	19.8	90.8	95	D6938	Fail
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/31/2026	8	20.6	101.1	Proctor 1	104.9	19.8	96.4	95	D6938	Pass
Location : Sewer line, Elv/Depth :3 to 4 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/31/2026
 Project No : 2026C125
 Client Company : Lewis Contracting
 Arrival Time : 03/31/2026 15:00
 Onsite Hours : 01:00

ASEC Report ID : 92526
 Name of the Project : Pittman Park - Garibaldi St. Stormwater
 Project Location : Atlanta
 Weather : Sunny
 Departure Time : 03/31/2026 16:00
 ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/28/2026	Proctor 1	104.9	19.8	Standard	Red, brown sandy SILT with some clay and GAB