

Date : 04/20/2026  
 Project No : 2026C125  
 Client Company : Lewis Contracting  
 Arrival Time : 04/20/2026 14:00  
 Onsite Hours : 02:00

ASEC Report ID : 93532  
 Name of the Project : Pittman Park - Garibaldi St. Stormwater  
 Project Location : Atlanta  
 Weather : Sunny  
 Departure Time : 04/20/2026 16:00  
 ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/20/2026	1	17.8	100.6	Proctor 1	104.9	19.8	95.9	98	D6938	Fail
Location : Storm line in parking lot, Elv/Depth :at finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
04/20/2026	2	15.1	100.1	Proctor 1	104.9	19.8	95.4	98	D6938	Fail
Location : Storm line in parking lot, Elv/Depth :at finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/20/2026  
 Project No : 2026C125  
 Client Company : Lewis Contracting  
 Arrival Time : 04/20/2026 14:00  
 Onsite Hours : 02:00

ASEC Report ID : 93532  
 Name of the Project : Pittman Park - Garibaldi St. Stormwater  
 Project Location : Atlanta  
 Weather : Sunny  
 Departure Time : 04/20/2026 16:00  
 ASEC Technician Name : Sean Willett

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/28/2026	Proctor 1	104.9	19.8	Standard	Red, brown sandy SILT with some clay and GAB