

Date : 05/12/2026  
 Project No : 2026C125  
 Client Company : Lewis Contracting  
 Arrival Time : 05/12/2026 12:00  
 Onsite Hours : 04:00

ASEC Report ID : 94367  
 Name of the Project : Pittman Park - Garibaldi St. Stormwater  
 Project Location : Atlanta  
 Weather : sunny  
 Departure Time : 05/12/2026 16:00  
 ASEC Technician Name : Samara Simha Reddy Kandi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
05/12/2026	1	18.8	99.9	Proctor 1	104.9	19.8	95.2	95	D6938	Pass
Location : Around 25ft from Manhole F1, Elv/Depth :-6"										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
05/12/2026	2	16.8	117.2	Proctor 1	104.9	19.8	95.6	95	D6938	Pass
Location : Around 50 ft from Manhole F1, Elv/Depth :-6"										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 05/12/2026  
Project No : 2026C125  
Client Company : Lewis Contracting  
Arrival Time : 05/12/2026 12:00  
Onsite Hours : 04:00

ASEC Report ID : 94367  
Name of the Project : Pittman Park - Garibaldi St. Stormwater  
Project Location : Atlanta  
Weather : sunny  
Departure Time : 05/12/2026 16:00  
ASEC Technician Name : Samara Simha Reddy Kandi

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/28/2026	Proctor 1	104.9	19.8	Standard	Red, brown sandy SILT with some clay and GAB