

Date : 06/17/2026  
Project No : 2026C133  
Client Company : Artisan  
Arrival Time : 06/17/2026 9:00  
Onsite Hours : -8:00

ASEC Report ID : 95372  
Name of the Project : Salacoa (AKA Boone Ford Rd) Robert's  
Dam  
Project Location : Calhoun  
Weather : clear and sunny  
Departure Time : 06/17/2026 1:00  
ASEC Technician Name : Narayana Ganesh Undavalli

---

**Location(S):**

**Testing:** 1 Set of concrete specimens (6 per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

**Compliance:**  Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)  
 Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

**Specimen Pick Up:** 1 Sets of concrete specimens/ 6 specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

**Field Curing:** Specimen were stored for the initial 24 hours  
 Near the poured structure  
 In an insulated curing box  
 Other

**Remarks:** concrete Temperature = 88 Ambient Temperature = 78 Slump = 3.5 Air = 2.3 unit wt of concrete = 143.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.