

Date : 05/18/2026
 Project No : 2026C142
 Client Company : KFE
 Arrival Time : 05/18/2026
 Onsite Hours : N/A

ASEC Report ID : 94660
 Name of the Project : Bailey Station Way
 Project Location : Sharpsburg
 Weather : sunny
 Departure Time : 05/18/2026
 ASEC Technician Name : Russell Hendrix

| Test Date | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|---|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 05/18/2026 | 1 | 16.1 | 110.5 | | | | Infinity | 90 | D6938 | Pass |
| Location : SE section, Elv/Depth :Unknown Comment : proctor unknown Tested By : Russell Hendrix Gauge Serial No. : 38069 | | | | | | | | | | |
| 05/18/2026 | 2 | 18.6 | 93.3 | | | | Infinity | 90 | D6938 | Pass |
| Location : North center, Elv/Depth :unknown Comment : proctor unknown Tested By : Russell Hendrix Gauge Serial No. : 38069 | | | | | | | | | | |
| 05/18/2026 | 3 | 20.5 | 94.0 | | | | Infinity | 90 | D6938 | Pass |
| Location : Southwest section, Elv/Depth :unknown Comment : proctor unknown Tested By : Russell Hendrix Gauge Serial No. : 38069 | | | | | | | | | | |

Remark: Test performed in general accordance with signed referenced ASTM Method.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 05/18/2026
Project No : 2026C142
Client Company : KFE
Arrival Time : 05/18/2026
Onsite Hours : N/A

ASEC Report ID : 94660
Name of the Project : Bailey Station Way
Project Location : Sharpsburg
Weather : sunny
Departure Time : 05/18/2026
ASEC Technician Name : Russell Hendrix

PROCTOR DATA SUMMARY

| TEST DATE | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|-----------|------------|--------------------------|----------------------|--------------|------------------|
|-----------|------------|--------------------------|----------------------|--------------|------------------|