

Date : 09/22/2025
Project No : 2025C245
Client Company : Bearing Engineering
Arrival Time : 09/22/2025 11:00
Onsite Hours : 03:00

ASEC Report ID : 86235
Name of the Project : Dunkin Donuts 2025
Project Location : US 29, Palmetto, GA
Weather : sunny
Departure Time : 09/22/2025 14:00
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site as requested by the contractor for the observation/testing of the placement of concrete for the cast in place wall footing. Concrete testing was performed from the middle of the sample out of the first concrete truck on site. The concrete appeared to have a high water/cement ratio. The slump test was recorded at 8.5 inches (as shown in picture). The contractor was informed of the test results. Five (5) cylinders were cast from this sample and will be transported to the lab once they have cured on site for 24 hours.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



cylinder curing container



footing

Date : 09/22/2025
Project No : 2025C245
Client Company : Bearing Engineering
Arrival Time : 09/22/2025 11:00
Onsite Hours : 03:00

ASEC Report ID : 86235
Name of the Project : Dunkin Donuts 2025
Project Location : US 29, Palmetto, GA
Weather : sunny
Departure Time : 09/22/2025 14:00
ASEC Technician Name : Sean Willett



footing



slump test

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.